

GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From :
The Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

To :
The District Educational Officer,
Krishna District.

Re.No. 15638/KRI/RFO/2020 (MSB-ER), Dated: 7-12-2021.

Sir,

Sub: A.P. State Disaster Response and Fire Services Department-MSB Section-Issuance of Renewal of No Objection Certificate to Existing Building of M/s Sri Viswasanthi Educational Institutions, represented by Madala Subrahmanyeswara Rao, R.S.No.206, Gandigunta, Vuyyur (M), Krishna District-Regarding.

Ref: 1. Occupancy NOC Re.No.15638/KRI/RFO/2020, Dt:01.02.2021 of Regional Fire Officer, Eastern Region, Vijayawada.
2. Application of M/s Sri Viswasanthi Educational Institutions, represented by Madala Subrahmanyeswara Rao, R.S.No.206, Gandigunta, Vuyyur (M), Krishna District.

The Management of M/s Sri Viswasanthi Educational Institutions, represented by Madala Subrahmanyeswara Rao, R.S.No.206, Gandigunta, Vuyyur (M), Krishna District has requested to issue Renewal of No Objection Certificate by duly remitting the Renewal fee towards Fire Precautionary fee vide reference 2nd cited.

2) The No Objection Certificate for Occupancy was issued vide reference 1st cited to the Existing Building of M/s Sri Viswasanthi Educational Institutions, represented by Madala Subrahmanyeswara Rao, R.S.No.206, Gandigunta, Vuyyur (M), Krishna District with Ground + 03 Upper Floors + Pent House with a Built-up area of 23811.38 Sq.Mtrs., with a Height of 14.50 Mtrs., for Educational Occupancy.

3) The management has submitted the Self-Certification report and stated that the furnished information is correct and it is noticed at any time that the information provided is false, they understand that Renewal NOC deemed may be cancelled by the concerned authority.

4) In view of the above and taking into consideration of the larger public interest and in the context of the COVID-19 pandemic across the country and also based on the Self-Certification submitted by the management, the Renewal of No Objection Certificate is issued to the Existing Building of M/s Sri Viswasanthi Educational Institutions, represented by Madala Subrahmanyeswara Rao, R.S.No.206, Gandigunta, Vuyyur (M), Krishna District with Ground + 03 Upper Floors + Pent House with a Built-up area of 23811.38 Sq.Mtrs., with a Height of 14.50 Mtrs., for Educational Occupancy subject to the condition that the Management shall provide the following Fire Fighting System and Electrical Safety System and to maintain in good working condition at all time.

K. Padmaja Vam

PRINCIPAL
Viswasanthi English Medium High School
Senior Secondary
Affiliated to CBSE, Delhi, Aff. No.130203
Gandigunta, VUYYURU-521 165.

Contd.....2P

For Viswasanthi Educational Society

M. Subrahmanyeswara Rao
Secretary, Correspondent & Treasurer

Sl. No.	Fire Fighting Equipment	Prescribed	Required	To be provided
1	Fire Extinguishers	ABC type	250 Nos.	Nil
2	Underground parking/ Cellar / Basement	Temperature Sensors connected " Hooter " and that can give alerts through Cell phone.	To be provided	To be provided
3	Manual Call Point System	One Number per Floor	02 Nos.	01 No.
4	Under Ground Static Water Tank (or) Terrace Water Tank	5,000 Ltrs. (minimum)	10000 Ltrs.	Nil
5	2 HP (Pump + Electrical Motors connected) @ one per Floor connected to Normal Plumbing System instead of Down Comer/Special Pipes.	One per each Floor	04 Nos.	Nil
6	5 HP (Mobile Pump + Petrol Engine on wheels connected to Ground Floor Sump)	One number	01 No.	01 No.

5) Electrical Safety System:

(i) Miniature Circuit Breakers, MCB's.	:	Yes/Provided
(ii) No Overloading of Power Sockets.	:	Yes
(iii) 10 years old wiring to be changed specially wherever A/c is there ?	:	Yes/Provided
(iv) LED Lights in Closed Rooms, Corridors, Staircases connected to Inverter (Battery).	:	Yes/Provided
(v) Grounding/Earthing is provided	:	Yes/Provided
(vi) Lightening Conductor is provided	:	NA
(vii) The above shall be certified by authorized Electrical Contractor/ Supervisor.	:	Yes/Provided

6) Fire Safety Suggestions:


Sl. No.	As Builder	As Occupant	As Security personnel
1.	All the Fire protection arrangements shall be maintained in good working condition at all time.	The Escape/Exit roots shall not be kept Locked/Blocked or Encroached.	All the occupants must be trained the correct method of operation of the Fire Fighting System installed.
2.	Any loss of life or property due to non-functioning of Fire Safety Measures and other Installations shall be the responsibility of the management.	All occupants shall be trained to operate the Fire Safety Equipment during Emergency.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.
3.	Addition/Alteration, if any in the Building may be verified by Building Authority.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.	All Security Personnel shall be trained to operate the Fire Safety Equipment during Emergency.
4.	This Annual Periodical Renewal Fire Certificate is only from Fire Safety Point of View.	Raise the alarm if the Fire cannot be controlled, Evacuate the area completely at once with nearest Safe Exit.	Attack the Fire using available Fire Equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing Doors and Windows.

Contd.....3P

Government of Karnataka
 Department of Urban Planning and Construction
 Bangalore

7) This Renewal of No Objection Certificate is valid for a period of Five years from the date of issue of this letter subject to the compliance of above Fire and Electrical Safety Measures. The Owner/Occupier/Builder/Management concerned of the Building shall submit Self Declaration/Certification with regard to working condition of above Fire Safety System every year in the prescribed format and submit/upload the photographs of the Mock Drills conducted in the premises. It is the responsibility of the Builder to maintain the Fire Safety Equipment in good working condition at all times and apply for next Periodical Renewal of No Objection Certificate, duly remitting the User Charges vide G.O.Ms.No.90, Home (Prisons & Fire Services) Department Dated:13.08.2021 & G.O.Ms.No.120, Home (Prisons & Fire Services) Department Dated:25.10.2021, two (02) months before expiry of this Renewal of No Objection Certificate.

Yours Sincerely,



Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

Copy to the Management, M/s Sri Viswasanthi Educational Institutions, represented by Madala Subrahmanyeswara Rao, R.S.No.206, Gandigunta, Vuyyur (M), Krishna District.
Copy to Regional Fire Officer, Eastern Region, Vijayawada.
Copy to District Fire Officer, Krishna.

Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.

K. Padmaja Vani

PRINCIPAL
Viswasanthi English Medium High School
Senior Secondary
Affiliated to CBSE, Delhi, Aff. No.130203
Gandigunta, VUYYURU-521 165.

For Viswasanthi Educational Society

M. Subrahmanyeswara Rao,
Secretary, Correspondent & Treasurer